

**OFFICE OF THE VICE CHANCELLOR**

Tel: 020 802 92 08  
Cell: 0716490014  
Web: [www.rongovarsity.ac.ke](http://www.rongovarsity.ac.ke)  
Email: [vc@rongovarsity.ac.ke](mailto:vc@rongovarsity.ac.ke)

P.O. Box 103,  
RONGO - 40404  
KENYA

Date: 1<sup>st</sup> November, 2018

**To: All bidders**

Dear Sir / Madam,

**TENDER NO. RU/OT/01/18-19 – THE PROPOSED SUPPLY AND INSTALLATION OF  
OVERHEAD POWER DISTRIBUTION NETWORK AND LOW VOLTAGE  
SWITCHGEAR AT RONGO UNIVERSITY**

Reference is made to a letter received on 31<sup>st</sup> October, 2018 from one of the bidders for the above tender seeking clarification on the following issues;-

1. The scope of works didn't capture the switch room for ground mounted transformer of KPLC and LV switchboard, therefore all feeders of mains supply will not be terminated on LV board without shelter due to ingress potechon standards. (IP).
2. Ali small load centers on the prop drawing (service line cables) are not captured on the scope.

We wish to respond as follows;-

A PC sum has been set aside for:


1. Transformer plinth and a cage as per Kenya Power standards.
2. Switch room to have the LV boards.

Kindiy refer to item 8.0 on the BQ summary of the scope. All new cables are captured in the BQ.

**Service line cables**

These are existing cables and are not part of the scope. All new cables are captured in the BQ.

Thank you.



**PROF. SAMUEL GUDU  
VICE CHANCELLOR**